

उत्तरी दिल्ली नगर निगम



NORTH DELHI MUNICIPAL CORPORATION
NARELA ZONE, NARELA, DELHI-110040

SCHOOL HEALTH CERTIFICATE

D. No. DHO/NRZ/2020-21/.....1339.....

DATE:- 2/3/2021

DATE OF INSPECTION : 02/03/2021

1. NAME OF SCHOOL : **BLOOMING DALES PUBLIC SCHOOL**
2. ADDRESS : **RAJENDRA PARK, ROHTAK ROAD, NANGLOI, DELHI-110041**
3. NO. OF SHIFTS : **ONE** TIMING: **08:00 AM TO 01:30 PM**

ACCOMODATION PROVIDED:-

THE FLOOR AREA IN THE CLASSROOM IS **SUFFICIENT.**

THE CLASSES ARE **WELL LIGHTED.**

THE CLASSROOMS ARE **WELL VENTILATED.**

THE CLASSROOMS ARE KEPT **NEAT AND CLEAN.**

THE DRINKING WATER IS **WATER TEST REPORT APPROVED BY DJB Lab..**

THE TOILET ARRANGEMENT IS **SANITARY &HYGIENIC AND SUFFICIENT IN NUMBER.**

REMARKS: THIS CERTIFICATE DOES NOT INDICATES PERMISSIBILITY FROM LAND POINT OF VIEW.

The certificate is valid for a period of one year from the date of issue.

The **PRINCIPAL**

BLOOMING DALES PUBLIC SCHOOL
RAJENDRA PARK, ROHTAK ROAD, NANGLOI,
DELHI-110041

Saty Ph
DY. HEALTH OFFICER
NARELA ZONE
Dy. Health Officer
Narela Zone



APEX TESTING AND RESEARCH LABORATORY

9/50, Kirti Nagar Industrial Area, New Delhi-110015
E-mail : info.apex2015@gmail.com
apex.testing.researchlab2015@gmail.com
Website : www.atrl.in, Tel.: 011-47081611, +91-8376945025
ISO 9001:2015 | ISO: 14001:2015
ISO 45001:2018 Certified | Govt. Approved Lab

TEST REPORT

Issued To : M/s. Blooming Dales Public School
: Rajendra Park, Rohtak Road
: Nangloi, Delhi-110041

Nature of the Sample : Drinking Water

Customer Ref. No : N.S

Brand Name : N.S

Sampling Method : N.S

Mfg. Date : N.S

Sample drawn by : N.S

Report /Sample No. : AS0920210103026

Date Of Receipt : 01.03.2021

Date of Issue : 05.03.2021

Test Started On : 01.03.2021

Test Completed on : 05.03.2021

Sample Quantity : 1 ltr.

Sample Pkg. : Pet Bottle

Best Before Date : N.S

Any Other Information : N.S

S. No	Test Parameters	Units of Measurements	Results	Requirement (IS: 10500-2012)		Method Reference
				Acceptable Limit	Permissible Limit	
PHYSICAL PARAMETERS						
1.	pH value	--	7.19	6.5-8.5	No Relaxation	IS:3025(P-11)-1983
2.	Colour	Hazen units	<1.0	5 max	15 max	IS:3025(P-4)-1983
3.	Odour	--	Agreeable	Agreeable	Agreeable	IS:3025(P-5)-1983
4.	Taste	--	Agreeable	Agreeable	Agreeable	IS:3025(P-7&8)-1984
5.	Turbidity	NTU	<1.0	1 max	5 max	IS:3025(P-10)-1984
6.	Total Dissolved Solids (TDS)	mg/l	131	500 max	2000 max	IS:3025(P-16)-1984
CHEMICAL PARAMETERS						
7.	Fluoride(as F)	mg/l	ND(DL-0.05)	1 max	1.5 max	IS:3025 (P-60)-2008
8.	Calcium (as Ca)	mg/l	6.0	75 max	200 max	IS:3025(P-40)-1991
9.	Magnesium (as Mg)	mg/l	2.1	30 max	100 max	IS:3025(P-46)-1994
10.	Chloride (as Cl)	mg/l	11.5	250 max	1000 max	IS:3025(P-32)-1988
11.	Sulphate (as SO ₄)	mg/l	2.9	200 max	400 max	IS:3025(P-24)-1986
12.	Total Hardness (as CaCO ₃)	mg/l	24.0	200 max	600 max	IS:3025(P-21)-2009
13.	Iron (as Fe)	mg/l	ND(DL-0.05)	1 max	No Relaxation	IS:3025(P-53)-2003
MICROBIOLOGICAL PARAMETERS						
1.	Coliform	MPN/100ml	Absent	Absent	Absent	IS:1622:1981
2.	E. coli	MPN/100ml	Absent	Absent	Absent	IS:1622:1981

Remarks: The sample conforms as per IS: 10500-2012 for drinking water purpose In acceptable limit w. r. t. above test parameters on

ND- Not Detected

DL- Detection Limit

Authorized Signatory
(Microbiological)

End of Report



Terms & Conditions : 1 Test reports are valid only for the samples tested in our laboratory. 2. Samples will destroyed after 30 days from the date of issue of test report unless specified. 3. Samples tested are Non-Returnable until specified at time of sample submission. 4. This report will not be valid for judicial purpose or for any other purpose.